



佳汇检测  
JIAHUI TESTING



232500340036

正本

报告编号: KS-SZ-20252473

# 检验报告

TEST REPORT

云南佳汇检测技术有限公司

Yunnan Jiahui Testing Technology Co.,Ltd.

检验检测专用章

# 声明

## Statement

1、本报告涂改无效，无编制、审核、批准人签章无效。

This report is invalid if altered. It is also invalid without the signatures and seals of the preparer, reviewer and approver.

2、本报告“封面”处未加盖本公司公章/检验检测专用章；“签发和骑缝”处未加盖本公司检验检测专用章无效。

This report is invalid if the company's official seal or inspection is not affixed on the "cover," or if the company's inspection is not affixed at the "issuance seal and binding edge seal" sections.

3、未经本公司批准不得部分复制（全文复制除外）此报告。

The report may not be partially reproduced (except for full text) without the approval of the Company.

4、检验检测项目中带“★”号者为分包检验检测项目。

The inspection and testing items marked with "★" are the subcontracted inspection and testing items.

5、对报告若有异议，委托方应于报告签收之日起十五日内向本公司提出。

Any objection to the report shall be raised by the Principal to the Company within 15 days from the date of receipt of the report.

6、当样品为送检时，检验检测报告对样品所检项目的符合性情况负责，送检样品的代表性和真实性由委托人负责。

When the sample is submitted for inspection, the inspection and testing report is responsible for the conformity of the inspected items of the sample. The representativeness and authenticity of the submitted sample are the responsibility of the client.

7、不得将本报告用于不当宣传。对非行政执法部门的委托检验，本报告不得作为决定、仲裁、裁决之用。

The report shall not be used for improper publicity. For the inspection commissioned by non-administrative law enforcement departments, this report shall not be used for decision, arbitration or award.

客户投诉电话：0871-67276798

传真 0871-67276798

Complaining phone number: 0871-67276798

Fax: 0871-67276798

邮箱：jhjc2017@126.com

邮政编码：650217

E-mail: [jhjc2017@126.com](mailto:jhjc2017@126.com)

Postal code: 650217

地址：中国（云南）自由贸易试验区昆明片区经开区阿拉街道办昌宏社区昌宏路 36 号

Address: No. 36, Changhong Road, Changhong Community, Ala Street, Economic Development Zone,

Kunming, China (Yunnan) Pilot Free Trade Zone

云南佳汇检测技术有限公司  
检验报告  
TEST REPORT

报告编号:KS-SZ-20252473

第1页 共2页

|                                    |                                                                                                             |                            |                 |
|------------------------------------|-------------------------------------------------------------------------------------------------------------|----------------------------|-----------------|
| 检品名称<br>Name of Sample             | 出厂水                                                                                                         | 收样编号<br>Original Number    | KS-2025-SZ-2284 |
| 来样方式<br>Method of Received         | 送检                                                                                                          | 采样人员<br>Sampling Personnel | 无               |
| 采集地点<br>Sampling Position          | 无                                                                                                           | 送样编号<br>Sample Number      | 寻甸出厂水           |
| 采样日期<br>Sampling Date              | 无                                                                                                           | 到样日期<br>Date of Received   | 2025年08月25日     |
| 检验日期<br>Date of Testing            | 2025年08月25日~2025年08月28日                                                                                     | 样品数量<br>Sum of Sample      | 1               |
| 样品状态<br>Status of Sample           | 无色透明液体                                                                                                      | 型号规格<br>Type               | 2.5L塑料桶: 1桶     |
| 检验类别<br>Test Purpose               | 委托检验                                                                                                        | 委托单编号<br>Number of Client  | KS-SZ-2025-1911 |
| 委托方<br>Applicant Name              | 寻甸回族彝族自治县自来水厂                                                                                               | 电话<br>Telephone            | 13888443838     |
| 检验项目<br>Test Item                  | 铝。                                                                                                          |                            |                 |
| 检验/判定依据<br>Test/Judgement Standard | 检验依据详见检验报告附页检验标准(方法)名称及编号(含年号), 判定依据为《生活饮用水卫生标准》(GB 5749-2022)。                                             |                            |                 |
| 检验结论<br>Conclusion                 | 检验结果满足《生活饮用水卫生标准》(GB 5749-2022)中表1生活饮用水水质常规指标限值要求, 所检项目检验合格。<br><br>签发日期 Date of issue: 2025年08月28日         |                            |                 |
| 备注<br>Comment                      | 1、与样品相关的信息为样品明示标识或委托方提供;<br>2、所出检验数据仅对来样负责;<br>3、当样品检验结果低于方法检出限时, 以“(<方法检出限值)”表示;<br>4、本报告壹式贰份, 正本壹份, 副本壹份。 |                            |                 |

编制: 廖云霞  
Compiled by:

审核: 海鑫  
Checked by:

批准: 李翠红  
Approved by:

云南佳汇检测技术有限公司

检验报告附页

TEST REPORT ATTACHED SHEET

报告编号:KS-SZ-20252473

第2页 共2页

| 序号       | 检验项目 | 检验标准(方法)名称<br>及编号(含年号)                                       | 单位   | GB 5749-2022<br>标准限值 | 检验结果   |
|----------|------|--------------------------------------------------------------|------|----------------------|--------|
| 1        | 铝    | 《生活饮用水标准检验方法 第6部分: 金属和类金属指标》(4.5电感耦合等离子体质谱法)GB/T 5750.6-2023 | mg/L | 0.2                  | 0.0835 |
| ——以下空白—— |      |                                                              |      |                      |        |

